

# Caledonian


## **Aluminium Conductor Cables**

www.caledonian-cables.com

marketing@caledonian-cables.com

### 1kV Screened ABC -Aerial Bundled Cables to AS/NZS 3599.1 (AL/XLPE /CWS/HDPE) 3C120

#### Light Duty Screen



#### **APPLICATIONS**

Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

#### **STANDARDS**

AS/NZS 3599.1

#### CABLE CONSTRUCTION

Phase Conductor: Circular compacted stranded H68 aluminium to BS2627.

Conductor Screen: Extruded semi-conductive layer.

Insulation:XLPE.

Insulation Screen:Extruded semi-conductive layer.

Metallic Screen:Copper wire screen.

Separator:Semi-conductive swellable tape.

Outer Sheath: HDPE.

Support Conductor: Galvanized steel wires.

Assembly: Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

#### **DIMENSION AND PARAMETERS**

No. of	Conducto	Nominal	Nominal	No.	Nominal	Salvanize	Approx.	Cable (	Continuo <b>แ</b>	Continuoแ	Continuou
Cores ×	Diameter	Insulation	Insulation	Diamter	Sheath	Steel	Overall	Weight	Current	Current	Current
Cross-		Thickness	Screen	of	Thickness	Wire	Diameter		Rating	Rating	Rating
sectional			Thickness	Screened		Stranding			(Still air)	(1m/	(2m/
Area				Wires						s wind)	s wind)
No.×mm²	mm	mm	mm	no x	mm	no./mm	mm	kg/km	Α	Α	Α
				mm							
3x120	12.8	3.4	0.8	25/0.85	1.8	19/2	69.8	3190	205	300	355