

Caledonian


Airport Cables www.caledonian-cables.com

marketing@caledonian-cables.com

SACS (Security Access Control System) Push Button Cable

FFX200 05mRZ1-F 2G0.5 (CU/MGT+XLPE/LSZH 2×0.5mmsq 300/500V class 5)





APPLICATIONS

The cables are multicore stranded flexible cables sheathed with thermoplastic LSZH compound. The cables have the ability to restrict the propagation of the flame in the event of a fire. This is especially important to slow down the spreading of the fire as the cables may pass from one area to another within a building. Applications can be found in control and power circuits, power stations, underground tunnels, lifts, escalators, and high-rise buildings.

FIRE PERFORMANCE

Basic design	BS 7629-1
Halogen Free	IEC 60754-1
No corrosive gas emission	IEC 60754-2
Minimum Smoke Emission	IEC 61034/1/2
Reduced Fire Propagation	IEC 60332-3C / NF C 32-070-2.2 (C1)
Flame Retardance	IEC 60332-1 / NF C 32-070-2.1 (C2)
Fire Resistance	IEC 60331 / NF C 32070-2.3(CR1)

VOLTAGE RATING

300/500V

CABLE CONSTRUCTION

Conductor: Plain annealed copper wire, stranded according to IEC(EN) 60228 class 5. Insulation: Mica glass tape covered by extruded cross-linked XLPE compound. Outer Sheath: Thermoplastic LSZH compound type LTS3 as per BS 7655-6.1.

PHYSICAL AND THERMAL PROPERTIES

Temperature range during operation (fixed state): $-30^{\circ}C - +90^{\circ}C$ Temperature range during installation (mobile state): $-20^{\circ}C - +50^{\circ}C$ Minimum bending radius: 8 × Overall Diameter

Electrical Properties

Dielectric test:2000 V r.m.s. x 5' (core/core)



Caledonian

Airport Cables www.caledonian-cables.com

marketing@caledonian-cables.com

Insulation resistance:1000 MΩ x km (at 20°C) Short circuit temperature:250°C

DIMENSION AND PARAMETERS

No. of Cores	Nominal Cross- sectional Area	No./Nominal Diameter of Strands	Nominal Insulation Thickness	Nominal Sheath Thickness	Nom. Overall Diameter	Approx. Weight
	mm²	no./mm	mm	mm	mm	kg/km
2	0.5	16/0.2	0.5	0.5	6.5	45



BS 7629-1











