



Caledonian


Mining Cables (AS_NZS Standard)

www.caledonian-cables.com

marketing@caledonian-cables.com

AS/NZS 1972:2006 Cables

Type 2S 1.1/1kV Individually and Collectively Screened 30C1.5



APPLICATIONS

These individually copper screened cables are used for wiring of machines or between machines and equipment where a rubber cable is desired. These cables are also used for longwall lighting circuits, and may contain pilot and control cores or twisted pair and screened cores.

STANDARDS

AS/NZS 1972:2006

AS/NZS 1125

AS/NZS 3808

CABLE CONSTRUCTION

Conductors: Stranded tinned annealed copper conductor.

Insulation: EPR.

Filling: Elastomer centre filler.

Individual Composite Screen (earth conductor): Tinned annealed copper braiding interwove with polyester yarn.

Collective Composite Screen (earth conductor): Tinned annealed copper braiding interwove with polyester yarn.

Sheath: Heavy duty CPE sheath.

DIMENSION AND PARAMETERS

No. of Cores	Nominal Cross-sectional Area	No./ Nominal Diameter of Strands	Core Screen Strand Size	Core Screen Area of Screen	Nominal Insulation Thickness	Nominal Sheath Thickness	Nom. Overall Diameter	Approx. Weight
	mm ²	no./mm	no./mm	mm ²	mm	mm	mm	kg/km
30	1.5	30/0.25	0.3	14	1	1.9	32.6	170