



Caledonian

PAS 5308 Instrumentation Cables www.caledonian-cables.com marketing@caledonian-cables.com

PAS 5308 Part 2 / Type 1 (Unarmoured Cables)

PVC-OS-PVC Stranded Conductor 2P2.5





APPLICATIONS

These cables are designed to connect electrical instrumentation and communication systems in and around process plants and similar applications. Generally used to transmit analogue or digital signals in measurement and process control where chemicals may be present.

CABLE CONSTRUCTION

Conductor:Annealed copper, mulitistranded(Class 2)to BS EN 60228 Insulation:PVC to BS EN 50290-2-21:2002,grade TI51 Pairing:Two insulated conductors uniformly twisted together with a lay not exceeding 100mm, Two-pair cables without individual pair screens (quads) shall have four cores laid in quad formation round a central dummy Binder tape:Non-hygroscopic binder tape of minimum thickness 0.023 mm Collective screen:Aluminium/polyester tape is applied over the laid up pairs metallic side down in contact with tinned copper drain wire, 0.5mm² Outer sheath:Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002,grade TM51

COLOUR CODE

Insulation: See technical information Outer Sheath: Generally black

PHYSICAL AND THERMAL PROPERTIES

Temperature range: above 0°C(fixed installation) -15°C to +65°C(during operation)

Electrical Properties

Conductor Area Size:2.5 mm² Conductor Stranding(No.xmm):7x0.67 Conductor resistance(max):7.6 ohm/km Insulation resistance(min): Individual conductor:5 Gohm/km Individual screen:1 Mohm/km



Caledonian

PAS 5308 Instrumentation Cables

www.caledonian-cables.com marketing@caledonian-cables.com

Capacitance unbalance at 1kHz(pair to pair screen):250 pF/250m Max. Mutual Capacitance @ 1kHz for Non OS or OS cables(except 1 pair and 2 pairs):105 pF/m Max. Mutual Capacitance @ 1kHz IS/OS cables (include 1 pair and 2 pairs):140 pF/m Max. L/R Ratio for adjacent cores(Inductance/Resistance):60 µH/ohm Test voltage:2000 V Rated voltage:300/500 V

DIMENSION AND PARAMETERS

No. of Pairs	Nominal Cross- sectional Area	No. and Dia. of Wires	Nominal Insulation Thickness	Nominal Sheath Thickness	Nom. Overall Diameter
	mm²	no./mm	mm	mm	mm
2	2.5	7/0.67	0.6	0.9	9.7