



Product Service

CERTIFICATE

No. B 098200 0049 Rev. 00

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product:

**PVC Insulated Non-sheath cables
(Single Core Cable for Switchgear and
Controlgear Wiring)**

Model(s):

**FGD100 1V-K (BS6231 Type BK),
FGD100 1V2-K (BS6231 Type CK)**

Parameters:

Rated voltage: 600/1000V
Conductors: Annealed copper conductor, class 5
Insulation: PVC Type TI 1
according to BS EN 50363-3 for cable type BK,
and type TI 3
according to BS EN 50363-3 for cable type CK
Size: 1 x 0.50mm² to 1 x 240mm²

Tested according to: BS 6231:2006

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105223177701

Valid until: 2028-01-09

Date, 2023-01-10

(Silvia Zou)