



Product Service

CERTIFICATE

No. B 098200 0030 Rev. 01

Holder of Certificate: **Caledonian Cables Limited**

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product:

**Flame retardant cables
(XLPE insulated LSZH sheathed Armoured
cables)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64100180526602

Valid until: 2028-08-20

Date, 2023-08-21

(Boris Ouyang)

CERTIFICATE

No. B 098200 0030 Rev. 01

Model(s): FTX300 1RZ1MAZ1-R (N2XRH),
FTX400 1RZ1MZ1-R (N2XRH)

Parameters:

Rated voltage: 600/1000V

Conductors: Plain or tinned copper wires

Insulation: XLPE, GP8

Bedding: LSZH

Armour: FTX300 1RZ1MAZ1-R (N2XRH): armoured with aluminium wire

FTX400 1RZ1MZ1-R (N2XRH): armoured with galvanized steel wire

Sheath: LSZH, LTS 1

Sizes: FTX300 1RZ1MAZ1-R (N2XRH): 1C x 50mm² to 1C x 1000mm²

FTX400 1RZ1MZ1-R (N2XRH): 2C x 1.5mm² to 4C x 400mm²,
5C x 1.5mm² to 5C x 70mm², 7C x 1.5mm² to 37C x 4mm²

Tested according to: BS 6724:2016