

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. B 098200 0035 Rev. 01

**Holder of Certificate:** **Caledonian Cables Limited**  
1/F., CMA Building, 64-66 Connaught Road Central,  
Central and Western District  
HONG KONG

**Certification Mark:**



**Product:** **Fire Resistant Cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 64105180658702

**Valid until:** 2024-12-26

**Date,** 2019-12-27

*Boris Ouyang*  
( Boris Ouyang )

A4 / 07.17



Product Service

# CERTIFICATE

No. B 098200 0035 Rev. 01

**Model(s):** FFX200 05SOZ1-U, FFX200 05SOZ1-R

## Parameters:

Rated voltage:	300/500V
Conductors:	Plain or tinned annealed copper wire, class 1(FFX200 05SOZ1-U), class 2(FFX200 05SOZ1-R)
Insulation:	Silicone rubber
Screen:	Aluminium/Polyester foil with circuit protective conductor (for 2, 3, 4 cores), or drain wire (for 7, 12, 19 cores)
Sheath:	Halogen free flame retardant compound
Size:	2 x 1.0 to 4.0 mm <sup>2</sup> , 3, 4 x 1.5 to 4.0 mm <sup>2</sup> , 7, 12 x 1.5 to 2.5 mm <sup>2</sup> , 19 x 1.5 mm <sup>2</sup> .
Fire resistance category:	BS 6387 CWZ EN 50200 PH120, EN 50200 Annex E

**Tested according to:** BS 7629-1:2015  
BS 6387:2013  
EN 50200:2015  
IEC 60332-3-24:2018  
IEC 60754-1:2011  
IEC 60754-2:2011  
IEC 61034-2:2005  
IEC 61034-2:2005/AMD1:2013

**Production Facility(ies):** 096882

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

