



Product Service

CERTIFICATE

No. B 098200 0047 Rev. 00

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product:

**Flame retardant cables
(600/1000V XLPE insulated & LSZH sheathed
cables)**

Model(s):

**FTX300 1RZ1-R (N2XH),
FTX400 1RZ1-R (N2XH)**

Parameters:

Rated voltage: 600/1000V
Conductors: Plain or tinned copper wires
Insulation: XLPE, Type GP8
Sheath: LSZH, Type LTS4
Size:
FTX300 1RZ1-R (N2XH): 1x1.5mm² to 1x1000mm²
FTX400 1RZ1-R (N2XH): 2x1.5mm² to 5x120mm²


Tested according to: BS 8573:2012

The product was tested on a voluntary basis and complies with the essential requirements.
The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.
All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105223104401

Valid until: 2027-08-22

Date, 2022-08-23


(Silvia Zou)