



Product Service

Attestation of Conformity

No. N8A 098200 0019 Rev. 01

Holder of Attestation: Caledonian Cables Limited1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG**Product:****PVC insulated, PVC sheathed flexible cords
Flexible cables with thermoplastic PVC
insulation****Model(s):****FGD200 05V2V2-F/ HT105 05V2V2-F
HAR Code: H05V2V2-F****Parameters:**

Rated voltage:	300/500V
Conductors:	Annealed copper wires, class 5
Insulation:	Thermoplastic compound of Type TI 3
Sheath:	Thermoplastic compound of Type TM 3
Size:	2, 3, 4 and 5 x 0.75 mm ² to 4mm ²

**Tested
according to:**EN 50525-2-11:2011
EN 50525-1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.:

64105233048201

Date, 2023-03-22
(Silvia Zou)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®