



Product Service

CERTIFICATE

No. B 098200 0020 Rev. 01

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product:

**PVC insulated, PVC sheathed flexible cords
Flexible cables with thermoplastic PVC
insulation**

Model(s):

**FGD200 05V2V2-F/ HT105 05V2V2-F
HAR Code: H05V2V2-F**

Parameters:

Rated voltage:	300/500V
Conductors:	Annealed copper wires, class 5
Insulation:	Thermoplastic compound of Type T1 3
Sheath:	Thermoplastic compound of Type TM 3
Size:	2, 3, 4 and 5 x 0.75 mm ² to 4mm ²

Tested according to: EN 50525-2-11:2011
EN 50525-1:2011

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105233048201
Valid until: 2028-03-21

Date, 2023-03-22


(Silvia Zou)