



Product Service

# CERTIFICATE

No. B 098200 0018 Rev. 01

**Holder of Certificate:** Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,  
Central and Western District  
HONG KONG

**Certification Mark:**



**Product:**

**PVC insulated, PVC sheathed flexible cords  
(Flexible cables with thermoplastic PVC  
insulation)**

**Model(s):**

**FGD200 05VV-F (CU/PVC/PVC 300/500V Class 5)  
BS Code:3182Y/3183Y/3184Y/3185Y  
HAR Code:H05VV-F**

**Parameters:**


Rated voltage: 300/500V  
Conductors: Annealed copper wires, class 5  
Insulation: Thermoplastic compound of Type TI 2  
Sheath: Thermoplastic compound of Type TM 2  
Size: 2, 3, 4 and 5 x 0.75 mm<sup>2</sup> to 4mm<sup>2</sup>

**Tested according to:** EN 50525-2-11:2011  
EN 50525-1:2011

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64105223177801  
**Valid until:** 2028-02-01

**Date,** 2023-02-02

  
( Silvia Zou )