



Product Service

Attestation of Conformity

No. N8A 098200 0006 Rev. 01

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Product: **Non-sheathed cables for fixed wiring
(Single core non-sheathed PVC cables)**

Model(s): **FGD100 07V2-U(H07V2-U), FGD100 07V2-R(H07V2-R),
FGD100 07V2-K(H07V2-K), FGD100 07V-U(H07V-U),
FGD100 07V-R(H07V-R), FGD100 07V-K(H07V-K)**

Parameters:

Rated voltage:	450/750V
Conductors:	Plain or tinned copper wires
Insulation:	Special PVC TI1 core insulation (V) Special PVC TI3 core insulation (V2);
Size:	FGD100 07V-U(H07V-U): 1.5mm ² to 10mm ² FGD100 07V-R(H07V-R): 1.5mm ² to 630mm ² FGD100 07V-K(H07V-K): 1.5mm ² to 240mm ² FGD100 07V2-U(H07V2-U): 1.5mm ² to 10mm ² FGD100 07V2-R(H07V2-R): 1.5mm ² to 35mm ² FGD100 07V2-K(H07V2-K): 1.5mm ² to 35mm ²

Tested according to: EN 50525-2-31:2011
EN 50525-1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105223075001

Date, 2022-06-24


(Silvia Zou)