

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. B 098200 0026 Rev. 00

**Holder of Certificate:** **Caledonian Cables Limited**  
1/F., CMA Building, 64-66 Connaught Road Central,  
Central and Western District  
HONG KONG

**Certification Mark:**



**Product:** **Fire Resistant Cables**  
**(Single Core Non-sheathed Power cables)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 64100180417101

**Valid until:** 2023-07-22

**Date,** 2018-07-23 ( Boris Ouyang )



Product Service

# CERTIFICATE

No. B 098200 0026 Rev. 00

**Model(s):** FFX100 07mZ1-U, FFX100 07mZ1-R,  
FFX100 07mZ1-K, FFX100 07mZ-U,  
FFX100 07mZ-R, FFX100 07mZ-K

**Parameters:**

Rated voltage	450/750V
Conductors:	Plain or tinned copper wire
Fire barrier:	Mica glass tape
Insulation:	LSZH compound
Size:	1C x 1.5mm <sup>2</sup> to 1C x 630mm <sup>2</sup>
Fire resistance category:	BS 6387 CWZ(OD≤20mm); BS 8491 120min(OD>20mm)

**Remark:**  
FFX100 07mZ1-U/R/K is identical with FFX100 07mZ-U/R/K  
except the type designation

**Tested according to:** BS 6387:2013  
BS 8491:2008  
IEC 60754-1:2011  
IEC 60754-2:2011  
IEC 61034-2:2005  
IEC 61034-2:2005/AMD1:2013

**Production Facility(ies):** 096882

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT