


Caledonian

Aluminium Conductor Cables www.caledonian-cables.com marketing@caledonian-cables.com

12.7/22kV Screened ABC –Aerial Bundled Cables to AS/NZS 3599.1 (AL/XLPE /CWS/HDPE) 3C50

Light Duty Screen



APPLICATIONS

Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

STANDARDS

AS/NZS 3599.1

CABLE CONSTRUCTION

Phase Conductor: Circular compacted stranded H68 aluminium to BS2627.

Conductor Screen:Extruded semi-conductive layer.

Insulation:XLPE.

Insulation Screen:Extruded semi-conductive layer.

Metallic Screen:Copper wire screen.

Separator:Semi-conductive swellable tape.

Outer Sheath:HDPE.

Support Conductor: Galvanized steel wires.

Assembly:Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

DIMENSION AND PARAMETERS

No. of	Conducto	Nominal	Nominal	No.	Nominal	Galvanize	Approx.	Cable (Continuo	Continuou	Continuou
Cores ×	Diameter	Insulation	Insulation	Diamter	Sheath	Steel	Overall	Weight	Current	Current	Current
Cross-	-	Thickness		of	Thickness		Diameter			Rating	Rating



Caledonian

Aluminium Conductor Cables

www.caledonian-cables.com

marketing@caledonian-cables.com

sectional Area			Screen Thickness	Screened Wires		Wire Stranding			Rating (Still air)	(1m/ s wind)	(2m/ s wind)
No.×mm²	mm	mm	mm	no x mm	mm	no./mm	mm	kg/km	A	A	A
3x50	8.1	5.5	0.8	25/0.85	1.8	19/2	69	2780	125	170	200