

Caledonian


Aluminium Conductor Cables

www.caledonian-cables.com

marketing@caledonian-cables.com

1kV Screened ABC -Aerial Bundled Cables to AS/NZS 3599.1 (AL/XLPE /CWS/HDPE) 3C150

Light Duty Screen



APPLICATIONS

Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

STANDARDS

AS/NZS 3599.1

CABLE CONSTRUCTION

Phase Conductor: Circular compacted stranded H68 aluminium to BS2627.

Conductor Screen: Extruded semi-conductive layer.

Insulation:XLPE.

Insulation Screen:Extruded semi-conductive layer.

Metallic Screen:Copper wire screen.

Separator:Semi-conductive swellable tape.

Outer Sheath: HDPE.

Support Conductor: Galvanized steel wires.

Assembly: Three XLPE insulated screened cores are bundled around the galvanized steel wires in a right hand lay.

DIMENSION AND PARAMETERS

No. of	Conducto	Nominal	Nominal	No.	Nominal	Galvanize	Approx.	Cable (Continuoแ	Continuo	Continuou
Cores ×	Diameter	Insulation	Insulation	Diamter	Sheath	Steel	Overall	Weight	Current	Current	Current
Cross-	•	Thickness	Screen	of	Thickness	Wire	Diameter		Rating	Rating	Rating
		·	Thickness			Stranding			(Still air)		



Caledonian

Aluminium Conductor Cables

www.caledonian-cables.com

marketing@caledonian-cables.com

sectional Area				Screened Wires						(1m/ s wind)	(2m/ s wind)
No.×mm²	mm	mm	mm	no x mm	mm	no./mm	mm	kg/km	А	Α	А
3x150	14.2	3.4	0.8	25/0.85	1.9	19/2	73	3530	235	340	400