





Caledonian

Aluminium Conductor Cables

www.caledonian-cables.com

marketing@caledonian-cables.com

6.35/11kV Non Screened ABC –Aerial Bundled Cables to AS/NZS 3599.1(AL/XLPE/HDPE) 3C150



APPLICATIONS

Three XLPE insulated cores are bundled around the AAAC/1120 support conductor in a right hand lay.

STANDARDS

AS/NZS 3599.1

CABLE CONSTRUCTION

Phase Conductor: Circular compacted stranded H68 aluminium to BS2627.

Conductor Screen: Extruded semi-conductive layer.

Insulation: XLPE.

Insulation Screen: Extruded semi-conductive layer.

Separator: Semi-conductive swellable tape.

Outer Sheath: HDPE.

Support Conductor: Aluminium alloy conductor (AAAC/1120).

Assembly: Three XLPE insulated cores are bundled around the AAAC/1120 support conductor in a right hand lay.

DIMENSION AND PARAMETERS

No. of Cores × Cross-sectional Area	Conductor Diameter	Nominal Insulation Thickness	Nominal Insulation Screen Thickness	Nominal Sheath Thickness	Approx. Overall Diameter	Cable Weight	AAAC/1120 Support Conductor Size	Continuous Current Rating (Still air)	Continuous Current Rating (1m/s wind)	Continuous Current Rating (2m/s wind)
No. × mm ²	mm	mm	mm	mm	mm	kg/km	no./mm	A	A	A
3x150	14.2	3.4	0.8	1.2	70.1	2840	19/3.5	255	380	460