





# Caledonian

Industrial Cables (UL Standard)

www.caledonian-cables.com

marketing@caledonian-cables.com

EPR/Copper Tape Shield/CPE, Medium-Voltage Power, Shielded 15KV, UL Type MV-105, 133% Ins. Level, 220 Mils 1C4/0AWG



## APPLICATIONS

These cables are suitable for use in wet or dry locations when installed in accordance with NEC, use in aerial, conduit, open tray and underground duct installations and use in direct burial if installed in a system with a ground conductor that is in close proximity, and conforms with NEC 250.4 (A) (5). Besides, they are installed in a broad range of commercial, industrial and utility projects such as pulp and paper mills, petrochemical plants, steel mills, textile mills, water and sewage treatment facilities, environmental protection systems, railroads, mines and fossil fuel utility generating stations.

## STANDARDS

National Electric Code (NEC)

ICEA S-93-639/NEMA WC74

UL 1072

ICEA S-97-682

AEIC CS8

Meets EPA 40 CFR, Part 261 for leachable lead content per TCLP method

UL 1685 (Sizes 1/0 AWG and larger) UL Flame Exposure Test

IEEE 1202 (70,000 BTU/hr)/CSA FT4

Optional Flame Tests: ICEA T-29-520 (210,000 BTU/hr)

## VOLTAGE RATING

15KV

## CABLE CONSTRUCTION

Conductor: Annealed bare copper Class B strand.

Extruded Strand Shield (ESS): Extruded thermoset semi-conducting stress-control layer over conductor.

Insulation: Ethylene Propylene Rubber (EPR) insulation, colored to contrast with the black conducting shield layers.

Extruded Insulation Shield (EIS): Thermoset semi-conducting polymeric layer free stripping from insulation.

Metallic Shield: 5 mil annealed copper tape with an overlap of 25%.

Jacket: Flame-retardant, moisture- and sunlight-resistant Chlorinated Polyethylene (CPE).

## DIMENSION AND PARAMETERS



# Caledonian

Industrial Cables (UL Standard)

[www.caledonian-cables.com](http://www.caledonian-cables.com)

[marketing@caledonian-cables.com](mailto:marketing@caledonian-cables.com)

AWG Size	Conduct Diameter in	Conduct Diameter mm	Nomina Diameter over Insulation (min.) in	Nomina Diameter over Insulation (min.) mm	Nomina Diameter over Insulation (max.) in	Nomina Diameter over Insulation (max.) mm	Nomina Jacket Thickness in	Nomina Jacket Thickness mm	Approx Overall Diameter in	Approx Overall Diameter mm	Approx Weight kg/ km	Approx Weight LBS/ MFT	Ampacit In Air	Ampacit GND.	Ampacit Tray
4/0	0.48	12.19	0.92	23.37	1.005	25.53	0.08	2.03	1.21	30.73	1857	1248	330	315	335