


Caledonian

Mining Cables (AS_NZS Standard) www.caledonian-cables.com marketing@caledonian-cables.com

AS/NZS 1802:2003 Reeling & Trailing Cables

Type 241 3.3KV 3C50





APPLICATIONS

These cables are designed for various uses, including main feeder cable for continuous miners, pump cable, and power supply cable. Overall semiconductive screen provides protective earth contact for any object breaching the sheath prior to contact with power conductors.

STANDARDS

AS/NZS 1802:2003 AS/NZS 1125 AS/NZS 3808 AS/NZS 5000.1

CABLE CONSTRUCTION

3×Conductors: Flexible stranded tinned annealed copper conductor.

Conductor Screen: Semiconductive compound.

Insulation: EPR.

Insulation Screen: Semiconductive elastomer.

Cradle Separator: Semiconductive PCP.

Overall Core Screen: Semiconductive PCP filling and covering.

3×Interstitial Earth Conductor: Semiconductive PCP covered flexible stranded tinned copper conductor.

1×Central Extensible Pilot: EPR covered flexible stranded tinned copper conductor.

Textile Reinforcement: Open-weave braid reinforcement.

Sheath: Heavy duty PCP sheath. Heavy duty CPE/CSP sheath can be offered upon request.

COLOUR CODE

Rotational sequence of core colours: Red, Black, White, Black, Blue, Black

DIMENSION AND PARAMETERS

Nominal	No./	Earth	Earth	Pilot	Pilot		Nominal	Nom.	Approx.
Cross-	Nominal	Conductor	Conductor	Conductor	Conductor	Insulation	Sheath	Overall	Weight
sectional	Diameter	Strand	Thickness	Strand	Thickness	Thickness	Thickness	Diameter	
Area	of	Size	of	Size	of				
	Strands		Covering		Covering				



Caledonian

Mining Cables (AS_NZS Standard)

www.caledonian-cables.com marketing@caledonian-cables.com

mm²	no./mm	no./mm	mm	no./mm	mm	mm	mm	mm	kg/km
50	380/0.4	120/0.3	1.2	40/0.2	0.8	3	6	55.2	450