

Caledonian


PAS 5308 Instrumentation Cables

www.caledonian-cables.com marketing@caledonian-cables.com

PAS 5308 Part 2 / Type 2 (Armoured Cables)

PVC-OS-SWA-PVC Stranded Conductor 20C0.5





APPLICATIONS

These cables are designed to connect electrical instrumentation and communication systems in and around process plants and similar applications. Generally used to transmit analogue or digital signals in measurement and process control where chemicals may be present. The armoured version are well adapted to underground use in industrial applications where chemical and mechanical protections are needed (refinery areas, chemical plant...).

CABLE CONSTRUCTION

Conductor: Annealed copper, mulitistranded (Class 5) to BS EN 60228

Insulation:PVC to BS EN 50290-2-21:2002,grade TI51

Binder tape: Non-hygroscopic binder tape of minimum thickness 0.023 mm

Collective screen:Aluminium/polyester tape is applied over the laid up pairs metallic side down in contact with tinned copper drain wire, 0.5mm²

Inner sheath: Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002, grade TM51

Armour: Galvanized steel wire armour

Outer sheath: Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002, grade TM51

COLOUR CODE

Insulation: up to 40 cores yellow with black numbers, 41 - 80 cores black with yellow numbers

Outer Sheath: Generally black

PHYSICAL AND THERMAL PROPERTIES

Temperature range: above 0°C(fixed installation) -15°C to +65°C(during operation)

Electrical Properties

Conductor Area Size:0.5 mm²
Conductor Stranding(No.xmm):16x0.2
Conductor resistance(max):39.7 ohm/km
Insulation resistance(min):



Caledonian

PAS 5308 Instrumentation Cables

www.caledonian-cables.com marketing@caledonian-cables.com

Individual conductor:5 Gohm/km Individual screen:1 Mohm/km

Max. L/R Ratio for adjacent cores(Inductance/Resistance):25 µH/ohm

Test voltage:2000 V Rated voltage:300/500 V

DIMENSION AND PARAMETERS

| No. of Cores | Nominal Cross- sectional Area | No. and Dia. of Wires | Nominal Insulation Thickness | Nominal Inner Sheath Thickness | Diameter Over Inner Sheath | Nominal Armour Wire Diameter | Nominal Outer Sheath Thickness | Nominal Diameter Over Armour | Nom. Overall Diameter |
|-----------------|--|-----------------------------|------------------------------------|---|-------------------------------------|---------------------------------------|---|---------------------------------------|-----------------------------|
| | mm² | no./mm | mm | mm | mm | mm | mm | mm | mm |
| 20 | 0.5 | 16/0.2 | 0.6 | 1 | 13.5 | 1.25 | 1.5 | 16 | 19 |