


# Caledonian

PAS 5308 Instrumentation Cables www.caledonian-cables.com marketing@caledonian-cables.com

#### PAS 5308 Part 2 / Type 2 (Armoured Cables)

PVC-OS-SWA-PVC Stranded Conductor 20C2.5





## **APPLICATIONS**

These cables are designed to connect electrical instrumentation and communication systems in and around process plants and similar applications. Generally used to transmit analogue or digital signals in measurement and process control where chemicals may be present. The armoured version are well adapted to underground use in industrial applications where chemical and mechanical protections are needed (refinery areas, chemical plant...).

#### CABLE CONSTRUCTION

Conductor:Annealed copper, mulitistranded(Class 2)to BS EN 60228 Insulation:PVC to BS EN 50290-2-21:2002,grade TI51 Binder tape:Non-hygroscopic binder tape of minimum thickness 0.023 mm Collective screen:Aluminium/polyester tape is applied over the laid up pairs metallic side down in contact with tinned copper drain wire, 0.5mm<sup>2</sup> Inner sheath:Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002,grade TM51 Armour:Galvanized steel wire armour Outer sheath:Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002,grade TM51

#### COLOUR CODE

Insulation: up to 40 cores yellow with black numbers, 41 - 80 cores black with yellow numbers Outer Sheath: Generally black

#### PHYSICAL AND THERMAL PROPERTIES

Temperature range: above 0°C( fixed installation) -15°C to +65°C(during operation)

#### **Electrical Properties**

Conductor Area Size:2.5 mm<sup>2</sup> Conductor Stranding(No.xmm):7x0.67 Conductor resistance(max):7.6 ohm/km Insulation resistance(min):



# Caledonian

PAS 5308 Instrumentation Cables

www.caledonian-cables.com

marketing@caledonian-cables.com

Individual conductor:5 Gohm/km Individual screen:1 Mohm/km Max. L/R Ratio for adjacent cores(Inductance/Resistance):60 µH/ohm Test voltage:2000 V Rated voltage:300/500 V

## DIMENSION AND PARAMETERS

No. of Cores	Nominal Cross- sectional Area	No. and Dia. of Wires	Nominal Insulation Thickness	Nominal Inner Sheath Thickness	Diameter Over Inner Sheath	Nominal Armour Wire Diameter	Nominal Outer Sheath Thickness	Nominal Diameter Over Armour	Nom. Overall Diameter
	mm²	no./mm	mm	mm	mm	mm	mm	mm	mm
20	2.5	7/0.67	0.6	1.3	19.9	1.6	1.7	23.1	26.5