


# Caledonian

## NEK606 Water Blocked Offshore & Marine Cables

www.caledonian-cables.com marketing@caledonian-cables.com

### Medium Voltage Power Cables

Water Blocked P2 or P2/P9 RFOU/TFOU 3.6/6KV 3C120



#### **APPLICATIONS**

These cables are partially water blocked, flame retardant, low smoke, halogen free and mud resistant, used for fixed installation for medium voltage power.

#### **STANDARDS**

IEC 60092-353

IEC 60092-360

IEC 60332-1

IEC 60332-3-22

IEC 60754-1,2

IEC 61034-1,2

**NEK 606** 

VG 95218 part 29

#### **VOLTAGE RATING**

0.6/1KV

#### **CABLE CONSTRUCTION**

Conductors: Circular tinned annealed stranded copper to IEC 60228 class 2.

Conductor Screen: Semi conducting material.

Insulation: Halogen-free EPR. XLPE can be offered as an option (for TFOU cable).

Insulation Screen: Semi conducting material and tinned copper wire braid.

Filler: Water blocking fillers, if required.

Bedding: Halogen free compound, PETP wrapping tape will be applied over the bedding, if required.

Armour: Tinned copper wire braid, PETP wrapping tape will be applied over the braiding, if required.

Water Blocking Elements: Water blocking tape and strings for providing longitudinal water tightness.

Inner Sheath: Halogen free thermosetting compound, SHF2 (for TYPE P2), or halogen free mud resistant thermosetting compound, SHF MUD (for TYPE P2/P9), coloured red.

Outer Sheath: Polyurethane for providing transversal water tightness, PE is optional, but can not meet low smoke standard.



# Caledonian

# NEK606 Water Blocked Offshore & Marine Cables

marketing@caledonian-cables.com www.caledonian-cables.com

# PHYSICAL AND THERMAL PROPERTIES

Bending Radius: 15×OD (during installation); 9×OD (fixed installed)

Temperature Range: -20°C ~ +90°C

# TECHNICAL CHARACTERISTICS

Nom. Cross- Section Area	Nom. Conductor Diameter	Maximum Resistance @20°C	Continuous Current Rating @45°C 1 Core	Short Circuit Current 1s
mm²	mm	Ohm/km	A	A
120	13.8	0.154	237	17170

# **DIMENSION AND PARAMETERS**

No. of Cores  × Cross- sectional Area	Nominal Insulation Thickness	Nominal Bedding Thickness	Nominal Inner Sheath Thickness	Nominal Outer Sheath Thickness	Nom. Overall Diameter	Cable Weight
No.×mm²	mm	mm	mm	mm	mm	kg/km
3×120	2.5	3	2.2	1.4	66.3±2	8573











