Report No.: GT(210)23008

# **TEST REPORT**

Name of sample: Airport Cable 400hz

Model no.: 0.6/1KV Power Cable

 $7 \times 50 \text{mm} + 6x(4x1 \text{mm} 2)$ 

Applicant: Caledonian Cables Limited

Manufacturer: Caledonian (Shandong ) Cables Limited

Address: 39 Chengbohu Road, Jibei Development Zone,

Jiyang District, JinanCity, Shandong, P.R. China

Issue date: 15 Feb. 2023

Deruixin Special Equipment Testing Co., Ltd

公田田公

# Attentions

- 1. The report is invalid without "special seal for inspection".
- 2. The copy report is invalid without being stamped with "special seal for testing" again.
- 3. The report is invalid without the signature of the chief inspector, reviewer and approver.
- 4. The report is invalid if altered.
- 5. If you have any objection to the test report, please notify the company in writing within 15 days from the date of receiving the report.
- 6. This test report is only responsible for the samples submitted for inspection.
- 7. Without the written approval of the Company, the report shall not be partially copied (except for full copy).

Testing laboratory: Deruixin Special Equipment Testing Co., Ltd Address: No. 93-5, Huihe Road, Yangting Town, Huancui District, Weihai City, Shandong P.R.China

Telephone: 0631-3809218 Postal code: 264200

**Deruixin Special** 

**Equipment Testing** 

**Test Report** 

Report No.: GT (210) 23008

Page 1 of 5

Co., Ltd

# **Test report**

Sample name	Airport Cable 400hz	Model No.	0.6/1KV Power Cable 7 x 50mm2+6x(4x1mm2)					
Qty of sample	1	Ref. No. of sample	230037					
Test of test	Commission Test	Date received	2023-02-10					
Consigner	Caledonian Cables Ltd	Testing date	2023-02-14					
Testing standards	Test method for electrical performance of the cable sample ,Ref. no: N23030	Testing items	<ul> <li>Cable voltage drop test</li> <li>Cable current carrying capacity</li> <li>Cable capacitance test</li> </ul>					
Purpose of the testing	□Development test □Qualification test □Type test ☑ Routine test							
Test result	The measured cable is connected to a three-phase AC power supply with the output frequency of 400Hz. Adjust the output current and measure the voltage drop of the cable; Measure the capacitance of the cable.  Please review Appendix C for test records.  Issue date: 2023-02-15							
Conclusion	The items tested comply with the requirement.							

Principal auditor:

Auditor:



**Deruixin Special** 

**Equipment Testing** 

**Test Report** 

Report No.: GT (210) 23008

Page 2 of 5

Co., Ltd

#### Appendix A: Testing circumstance

#### A.1 Test location

Power supply laboratory of Deruixin Special Equipment Testing Co., Ltd

#### A.2 Test equipment

#### A.1 Test equipment

No.	Name of equipment	Model No.	Validity of Calibration	Remarks
1	Testing instruments for resistance, capacitance	ZG025	2023-7-8	
2	Clamp ammeters	LZS-22	2023-3-1	
3	Multimeter	LZS-23	2023-3-1	

#### Appendix B: Cable sample

# **B.1 Sample information**

No.	Name	Manufacturer	Model no.	Sample no.	
1	Airport Cable	Caledonian (Shandong ) Cables	0.6/1KV Power Cable	230037	
	1	Ltd	$7 \times 50 \text{mm} 2 + 6 \times (4 \times 1 \text{mm} 2)$	230037	

# Appendix C: Test records

# C.1 Test records of cable voltage drop performance

Ambient temperature: 15.0 ℃

Ambient humidity: 66.8 % RH

Atmospheric pressure: 100.8 kPa

Power @400hz, φ=0,8, 90kW, 25meter

Load	Phase Current(A)		Phase Voltage of Head (V)		Phase Voltage of End (V)		Voltage drop of End					
	Ia	$I_b$	Ic	Uan	Ubn	Uen	$U_{ m an}$	$U_{ m bn}$	$U_{ m cn}$	∆ U <sub>an</sub>	$\Delta\mathrm{U_{bn}}$	∆ Ucn
No load	0	0	0	115.51	115.54	115.48	115.51	115.55	115.48	-	-	
Load-Current 270A	271.7	271.6	276.1	116.89	117.30	117.45	114.62	115.21	115.33	2.27v/ 0.3226mV/ Am	2.09v/ 0.2971mV/ Am	2.12v/ 0.2965mV/ Am
Load-Current 329A	338.7	332.3	339.2	117.18	117.77	117.80	114.59	115.29	115.28	2.59v/ 0.2952mV/ Am	2.48v/ 0.2882mV/ Am	2.52v/ 0.2868mV/ Am

Page 3 of 5

Co., Ltd

# C.2 Test records for cable capacitance

Cable size	Length(m )	2 ends of the testing	Capacitance (nF)	Remarks	
	25.9	N—a1	2.37		
		N—a2	2.27		
7×50mm²		N—b1	2.38		
		N—b2	2.36	==	
		N—c1	2.53		
		N—c2	2.50		
		c1—a1	2.55		
		a1—a2	1.74		

# Appendix D: Testing pictures



Cable picture before testing



Current capacity1




Voltage drop test1



Current capacity2



Voltage drop test2



Capacitance test



Capacitance test



Testing system



400hz power



Load 90kw

**Deruixin Special** 

**Equipment Testing** 

**Test Report** 

Report No.: GT (210) 23008

Page 5 of 5

Co., Ltd

# Appendix E: Attendance

Deruixin Special Equipment Testing Co., Ltd: Xiaolei Qu. Xiaoming Yu. Caledonian Cables Ltd: Alice Zhang.

—End of the report—



