



缆慧检测



170921341513



中国认可  
国际互认  
检测  
TESTING  
CNAS L9930

Report No.: TN18-02269E

Date: September 29<sup>th</sup>, 2018

Page 1 of 3

Contract No.: CN18-02463

Contract No.: ISTCW18-01137

Commission Test

## Test Report

Consigner	Caledonian Cables Limited 1/F, CMA Building, 64-66 Connaught Road Central, Hong Kong
Sample Name	Composite Cable
Type and Size	CALEDONIAN CC--RG59-2P0.22-3G2.5-H(SWB)H COMPOSITE CABLE
Sample Received Date	September 14 <sup>th</sup> , 2018
Test Duration	September 14 <sup>th</sup> , 2018 – September 29 <sup>th</sup> , 2018
Test Conclusion	The test items comply with the requirements of IEC 60332-3-22:2009 and IEC 60332-1-2:2004+A1:2015 respectively.

This test report is only valid for the tested sample.

Authorized by  
Shanghai Intelligent Service and Technology Co., Ltd.

李骥 Li Ji

Signature/Approver

Genuine statement: Without the written permission of ISTCW, the test report shall be reproduced in full. Its electronic version (such as PDF format or scanned version) is allowed to use, whatever with "only for information". This test report is only valid in paper version with both authorized signature as approved and dedicated inspection stamp of our company.

Testing Engineer: 黄宇 Huang Yu

Floor 1, Building 2, No. 258 Jinzang Road, Pudong New District, Shanghai, P.R.China

Telephone: +86-4008526288

Zip code: 201206

Fax: +86-21-50680618

Website: [www.istcw.com](http://www.istcw.com)

E-mail address: [service@istcw.com](mailto:service@istcw.com)

**CALEDONIAN CC--RG59-2P0.22-3G2.5-H(SWB)H COMPOSITE CABLE****1 Sample Description**

Manufacturer	Caledonian Cables Limited Northeast Plant, Inside of Dianliu Industrial Park, Shizi Park, DongJia Town, Licheng District, Jinan City, Shangdong Province
Type and Size	CALEDONIAN CC--RG59-2P0.22-3G2.5-H(SWB)H COMPOSITE CABLE
Quantity	110m
Marking	/
Color	Black
Source	Sent by the consigner
Status	Normal appearance

**2 Testing and Verdict Standards****2.1 Testing Standards**

IEC 60332-3-22: 2009	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A
IEC 60332-1-2:2004+A1:2015	Test on electric and optical fibre cables under fire conditions- Part 1-2: Test for vertical flame propagation for a single insulated wire or cable- Procedure for 1kW pre-mixed flame

**2.2 Verdict Standards**

The same as testing standards.

**3 Other Information****3.1 Sample information**

The sample's type and size, and manufacture information are provided by the consigner;

**3.2 Information from the test laboratory**

The following items are carried out at No.458 Haixiang Road, Fengxian, Shanghai, P.R.China:  
- Burning test for bunched cables Category A

**3.3 Verdict Symbol Definition**

P=Complying with requirement (Pass); F=Not complying with requirement (Fail); N=Not required.



**CALEDONIAN CC--RG59-2P0.22-3G2.5-H(SWB)H COMPOSITE CABLE**
**4 Burning test for bunched cables Category A**

Test method: IEC 60332-3-22: 2009.

Test parameters:

Total volume of non-metallic	7	L/m
Number of test pieces	23	
Number of layers	2	(14/9)
Positioning of test pieces	Touched	
Number of burners	1	
Flame application time	40	min

Test Item	Unit	Requirement	Test Result	Verdict
- Maximum extent of the charred portion above the bottom edge of the burner	m	≤2.5	0.58	P
- Time to extinction of all burning or glowing	h	/	<0.02	N

**5 Test for vertical flame propagation for a single cable**

Test method: IEC 60332-1-2:2004+A1:2015.

Test parameters:

Length of sample:	600	mm
Pretreatment temperature:	26	°C
Pretreatment relative humidity:	52	%
Pretreatment time:	16	h
Flame application time:	60	s

Test Item	Unit	Requirement	Test Result	Verdict
- the distance between the lower edge of the top support and the onset of charring	mm	>50	437	P
- the distance from the lower edge of the top support to the lower onset of charring	mm	≤540	523	P

- The End. -